



GRANDSTANDS/BLEACHERS INSPECTION CHECKLIST SUPPLEMENT

Building: _____ **Completed by:** _____ **Date:** _____

TO BE USED WITH ALL BUILDINGS/MAIN OFFICE CHECKLIST

ITEM	YES	NO	ACTION ITEM
Grandstands/Bleachers			
Are all openings less than 4 inches?			
Are guardrails present at heights more than 30 inches from the ground?			
Are guardrails secure and capable of supporting weight of people leaning?			
Are seats and handrails free of splinters or protruding objects?			
Do foundations, floorboards, supports and brackets show evidence of deterioration or degradation?			
Site Control			
Are barriers or methods in place to protect spectators from events?			
Are there barriers or methods to direct crowds safely?			

Checklists are developed using generally accepted safety and risk management standards. This checklist does not guarantee compliance with any building code, or federal, state or local regulations regarding safety or fire. Compliance does not ensure the absolute safety of your operations.